210900110152

W026061020579

5M1Yn1cM

检 测 报 告

Test Report

产品名称： Name of Sample	直饮水
规格型号： Type	/
委托单位： Applicant	上海市园南中学（罗城路校区）
检测类别： Test Purpose	委托检测

上海市质量监督检验技术研究院有限公司
Shanghai Institute of Quality Inspection and Technical Research Co., Ltd.

上海市质量监督检验技术研究院有限公司
检 测 报 告

报告编号：W026061020579

样品名称	直饮水	**检测类别**	委托检测
型号规格 等 级	/ /	**商标**	/
委托单位	上海市园南中学（罗城路校区）		
受检单位	/		
标称生产单位	/		
委托书编号	W026061020578	**委托/抽样日期**	2026.10.15
到样日期	2026.10.15	**抽样地点**	/
样品数量	1.5L×9	**受检批数量**	/
生产日期	/	**批号/编号**	/
样品到样状态	完好　　委托采样		
检测地点	上海市苍梧路381号		
检测依据	GB/T 5750.12-2023《生活饮用水标准检验方法 第12部分：微生物指标》 GB/T 5750.4-2023《生活饮用水标准检验方法 第4部分：感官性状和物理指标》 GB/T 5750.7-2023《生活饮用水标准检验方法 第7部分：有机物综合指标》		
判定依据	GB 5749-2022《生活饮用水卫生标准》		
检测日期	2026年10月15日 **至** 2026年10月22日		
检测结论	该样品本次所检项目检测结果符合上述检测依据/判定依据相关规定。详见本报告检测结果汇总页。 （检测报告专用章） 签发日期：2026年10月22日		
委托单位 通讯资料	**地址**：上海市徐汇区罗城路128号 **邮编**：/　　**电话**：/		
备注	本报告检验检测结论是根据检验检测依据/判定依据仅对所检项目得出的，不代表未经检验检测的项目或功能符合要求。 1#A-1F；2#B-1F；3#C-1F；4#E-1F；5#A-2F；6#B-2F；7#C-2F；8#D-2F；9#E-2F；10#A-3F；11#B-3F；12#C-3F；13#D-3F；14#E-3F；15#C-4F；16#D-4F；17#E-4F；18#A-5F；19#B1网球场；20#图书馆；21#B-4F；22#E-5F；工艺：超滤 注意事项、声明及所属单位一览表为本报告的组成部分。		

批准： 陈欣钦　　**审核：**　　**主检：**

检 测 报 告

报告编号：W026061020579

检测结果汇总

序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
1	总大肠菌群 MPN/100mL	不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	1#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	2#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	3#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	4#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	5#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	6#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	7#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	8#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	9#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	10#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	11#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	12#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	13#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	14#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	15#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	16#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	17#

检 测 报 告

报告编号：W026061020579

检测结果汇总

序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
1	总大肠菌群 MPN/100mL	不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	18#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	19#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	20#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	21#
		不应检出	未检出（<2）	GB/T 5750.12-2023(5.1)	符合	22#
2	菌落总数 CFU/mL	≤100	78	GB/T 5750.12-2023(4.1)	符合	1#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	2#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	3#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	4#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	5#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	6#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	7#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	8#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	9#
		≤100	65	GB/T 5750.12-2023(4.1)	符合	10#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	11#
		≤100	<1	GB/T 5750.12-2023(4.1)	符合	12#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
2	菌落总数 CFU/mL	≤100	＜1	GB/T 5750.12-2023(4.1)	符合	13#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	14#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	15#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	16#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	17#
		≤100	23	GB/T 5750.12-2023(4.1)	符合	18#
		≤100	20	GB/T 5750.12-2023(4.1)	符合	19#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	20#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	21#
		≤100	＜1	GB/T 5750.12-2023(4.1)	符合	22#
3	色度(铂钴色度单位) 度	≤15	＜5	GB/T 5750.4-2023(4)	符合	1#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	2#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	3#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	4#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	5#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	6#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	7#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
3	色度(铂钴色度单位) 度	≤15	＜5	GB/T 5750.4-2023(4)	符合	8#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	9#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	10#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	11#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	12#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	13#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	14#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	15#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	16#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	17#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	18#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	19#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	20#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	21#
		≤15	＜5	GB/T 5750.4-2023(4)	符合	22#
4	臭和味	无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	1#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	2#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
4	臭和味	无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	3#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	4#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	5#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	6#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	7#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	8#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	9#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	10#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	11#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	12#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	13#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	14#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	15#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	16#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	17#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	18#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	19#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
4	臭和味	无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	20#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	21#
		无异臭、异味	无异臭、异味	GB/T 5750.4-2023(6.1)	符合	22#
5	肉眼可见物	无	无	GB/T 5750.4-2023(7.1)	符合	1#
		无	无	GB/T 5750.4-2023(7.1)	符合	2#
		无	无	GB/T 5750.4-2023(7.1)	符合	3#
		无	无	GB/T 5750.4-2023(7.1)	符合	4#
		无	无	GB/T 5750.4-2023(7.1)	符合	5#
		无	无	GB/T 5750.4-2023(7.1)	符合	6#
		无	无	GB/T 5750.4-2023(7.1)	符合	7#
		无	无	GB/T 5750.4-2023(7.1)	符合	8#
		无	无	GB/T 5750.4-2023(7.1)	符合	9#
		无	无	GB/T 5750.4-2023(7.1)	符合	10#
		无	无	GB/T 5750.4-2023(7.1)	符合	11#
		无	无	GB/T 5750.4-2023(7.1)	符合	12#
		无	无	GB/T 5750.4-2023(7.1)	符合	13#
		无	无	GB/T 5750.4-2023(7.1)	符合	14#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
5	肉眼可见物	无	无	GB/T 5750.4-2023(7.1)	符合	15#
		无	无	GB/T 5750.4-2023(7.1)	符合	16#
		无	无	GB/T 5750.4-2023(7.1)	符合	17#
		无	无	GB/T 5750.4-2023(7.1)	符合	18#
		无	无	GB/T 5750.4-2023(7.1)	符合	19#
		无	无	GB/T 5750.4-2023(7.1)	符合	20#
		无	无	GB/T 5750.4-2023(7.1)	符合	21#
		无	无	GB/T 5750.4-2023(7.1)	符合	22#
6	pH	6.5～8.5	7.52	GB/T 5750.4-2023(8.1)	符合	1#
		6.5～8.5	7.54	GB/T 5750.4-2023(8.1)	符合	2#
		6.5～8.5	7.72	GB/T 5750.4-2023(8.1)	符合	3#
		6.5～8.5	7.70	GB/T 5750.4-2023(8.1)	符合	4#
		6.5～8.5	7.49	GB/T 5750.4-2023(8.1)	符合	5#
		6.5～8.5	7.56	GB/T 5750.4-2023(8.1)	符合	6#
		6.5～8.5	7.65	GB/T 5750.4-2023(8.1)	符合	7#
		6.5～8.5	7.58	GB/T 5750.4-2023(8.1)	符合	8#
		6.5～8.5	7.69	GB/T 5750.4-2023(8.1)	符合	9#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
6	pH	6.5～8.5	7.59	GB/T 5750.4-2023(8.1)	符合	10#
		6.5～8.5	7.60	GB/T 5750.4-2023(8.1)	符合	11#
		6.5～8.5	7.58	GB/T 5750.4-2023(8.1)	符合	12#
		6.5～8.5	7.50	GB/T 5750.4-2023(8.1)	符合	13#
		6.5～8.5	7.62	GB/T 5750.4-2023(8.1)	符合	14#
		6.5～8.5	7.53	GB/T 5750.4-2023(8.1)	符合	15#
		6.5～8.5	7.66	GB/T 5750.4-2023(8.1)	符合	16#
		6.5～8.5	7.67	GB/T 5750.4-2023(8.1)	符合	17#
		6.5～8.5	7.61	GB/T 5750.4-2023(8.1)	符合	18#
		6.5～8.5	7.57	GB/T 5750.4-2023(8.1)	符合	19#
		6.5～8.5	7.52	GB/T 5750.4-2023(8.1)	符合	20#
		6.5～8.5	7.61	GB/T 5750.4-2023(8.1)	符合	21#
		6.5～8.5	7.74	GB/T 5750.4-2023(8.1)	符合	22#
7	浑浊度(散射浑浊度单位) NTU	≤1	＜0.5	GB/T 5750.4-2023(5.1)	符合	1#
		≤1	＜0.5	GB/T 5750.4-2023(5.1)	符合	2#
		≤1	＜0.5	GB/T 5750.4-2023(5.1)	符合	3#
		≤1	＜0.5	GB/T 5750.4-2023(5.1)	符合	4#

检 测 报 告

报告编号：W026061020579

检测结果汇总

序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
7	浑浊度(散射浑浊度单位) NTU	≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	5#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	6#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	7#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	8#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	9#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	10#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	11#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	12#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	13#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	14#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	15#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	16#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	17#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	18#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	19#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	20#
		≤1	<0.5	GB/T 5750.4-2023(5.1)	符合	21#

检 测 报 告

报告编号：W026061020579

检测结果汇总						
序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
7	浑浊度(散射浑浊度单位) NTU	≤1	＜0.5	GB/T 5750.4-2023(5.1)	符合	22#
8	高锰酸盐指数($以O_2$计) mg/L	≤3	0.64	GB/T 5750.7-2023(4.1)	符合	1#
		≤3	0.68	GB/T 5750.7-2023(4.1)	符合	2#
		≤3	0.56	GB/T 5750.7-2023(4.1)	符合	3#
		≤3	0.68	GB/T 5750.7-2023(4.1)	符合	4#
		≤3	0.70	GB/T 5750.7-2023(4.1)	符合	5#
		≤3	0.62	GB/T 5750.7-2023(4.1)	符合	6#
		≤3	0.72	GB/T 5750.7-2023(4.1)	符合	7#
		≤3	0.56	GB/T 5750.7-2023(4.1)	符合	8#
		≤3	0.60	GB/T 5750.7-2023(4.1)	符合	9#
		≤3	0.66	GB/T 5750.7-2023(4.1)	符合	10#
		≤3	0.70	GB/T 5750.7-2023(4.1)	符合	11#
		≤3	0.68	GB/T 5750.7-2023(4.1)	符合	12#
		≤3	0.72	GB/T 5750.7-2023(4.1)	符合	13#
		≤3	0.60	GB/T 5750.7-2023(4.1)	符合	14#
		≤3	0.70	GB/T 5750.7-2023(4.1)	符合	15#
		≤3	0.62	GB/T 5750.7-2023(4.1)	符合	16#

检 测 报 告

报告编号：W026061020579

检测结果汇总

序号	检测项目	技术要求	检测结果	检测依据	单项判定	备注
8	高锰酸盐指数（以O_2计） mg/L	≤3	0.70	GB/T 5750.7-2023(4.1)	符合	17#
		≤3	0.72	GB/T 5750.7-2023(4.1)	符合	18#
		≤3	0.64	GB/T 5750.7-2023(4.1)	符合	19#
		≤3	0.60	GB/T 5750.7-2023(4.1)	符合	20#
		≤3	0.68	GB/T 5750.7-2023(4.1)	符合	21#
		≤3	0.64	GB/T 5750.7-2023(4.1)	符合	22#

（以下空白）

注 意 事 项

Notices

1、 报告无“检验检测专用章”或检测单位公章无效。

The report is valid with the "special seal for inspection and testing" or the official seal of SQI.

2、 不得部分复制报告，复制报告须加盖“检验检测专用章”或检测单位公章，否则无效。

The report shall not be reproduced except in full. The copied report is valid with the "special seal for inspection and testing" or the official seal of SQI.

3、 报告无主检/编制、审核、批准人签名无效。

The report is valid with signature of major inspector, reviewer and approver.

4、 报告涂改无效。

The report is invalid with any alteration or falsification.

授权国家质检中心名称

National Center of Quality Inspection and Testing

1、国家日用消费品质量检验检测中心

National Center of Quality Inspection and Testing on Consumer Goods

2、国家家具质量检验检测中心

National Center of Quality Inspection and Testing on Furniture

3、国家建筑材料及装饰装修材料质量检验检测中心

National Center of Quality Inspection and Testing on Building and Decoration Materials

4、国家智能电网分布式电源装备质量检验检测中心（上海）

National Center of Quality Inspection and Testing on Distributed Power Equipment in Smart Grid (Shanghai)

5、国家电器能效与安全质量检验检测中心

National Center of Quality Inspection and Testing on Energy Efficiency and Safety of Electrical Appliance

6、国家食品质量检验检测中心（上海）

National Center of Quality Inspection and Testing on Food Products (Shanghai)

7、国家保洁产品质量检验检测中心

National Center of Quality Inspection and Testing on Cosmetics and Cleaning Products

8、国家电光源质量检验检测中心（上海）

National Center of Inspection and Testing on Electric Light Source Quality (Shanghai)

9、国家灯具质量检验检测中心

China National Lighting Fitting Quality Inspection and Testing Centre (CLTC)

声 明

Statement

1、 本质检机构保证检测的科学性、公正性和准确性，对检测的数据、结果负责，并对客户所提供的样品和技术资料保密。

SQI pledges to conduct scientific, impartial and accurate testing, undertakes the liability of testing data and results, and protects the confidentiality of client(s)' sample(s) and technical information.

2、 对送样委托检测报告若有异议，应于报告收到之日起十五日内向本质检机构提出，逾期不予受理。

Any objection to the test report of delivered samples shall be submitted to SQI within 15 days from the date of receiving the report; overdue submission will not be accepted.

3、 对于非本质检机构实施抽样的检测报告，检测结果仅适用于客户提供的样品。

For the test report not sampled by SQI, the test results hereon refer only to the sample(s) provided by the client.

4、 未经本质检机构同意，委托人不得擅自使用检测数据、结果进行不当宣传。

Without prior approval of SQI, any client shall not use the testing data and results for improper publicity.

5、本质检机构在资质认定证书确定的能力范围内，对社会出具具有证明作用数据、结果时，应当标注检验检测机构资质认定标志，并加盖检验检测专用章。在资质认定证书确定的能力范围外，出具的检验检测报告或者证书上不得标注检验检测机构资质认定标志，该数据、结果对社会不具有证明作用。

Within the capacity scopes of Qualification Accreditation Certificates, SQI shall issue data and results with proving effect to the society with the symbol of China Inspection Body and Laboratory Mandatory Approval (CMA) and the special seal for inspection and testing of SQI. Beyond the capacity scopes of Qualification Accreditation Certificates, SQI shall not issue test reports or certificates with the symbol of China Inspection Body and Laboratory Mandatory Approval (CMA), and the data and results thereon have no proving effect to the society.

上海市质量监督检验技术研究院有限公司所属单位一览表

List of Subordinate Units of Shanghai Institute of Quality Inspection and Technical Research Co., Ltd. (SQI)

1. 食品化学品质量检验所(代码 SP) / 国家食品质量检验检测中心(上海) / 国家保洁产品质量检验检测中心 / 上海市食品质量监督检验站

Institute of Quality Inspection of Food and Chemicals (SQI_SP) / National Center of Quality Inspection and Testing on Food Products (Shanghai) / National Center of Quality Inspection and Testing on Cosmetics and Cleaning Products / Shanghai Municipal Station of Quality Supervision and Inspection of Food Products

地址：上海市徐汇区苍梧路 381 号　　邮编：200233
电话：021-54263362　　传真：021-54265730
地址：上海市奉贤区平庄西路 3086 号（日化产品）　　邮编：201499
电话：021-57493107　　传真：021-57493162
E-mail：shihuas@sqi.org.cn
Address: No.381, Cangwu Rd., Xuhui District, Shanghai　　Post: 200233
Tel: 021-54263362　　Fax: 021-54265730
Address: No.3086, West Pingzhuang Rd., Fengxian District, Shanghai (Daily Chemical Products)　　Post: 201499
Tel: 021-57493107　　Fax: 021-57493162
E-mail: shihuas@sqi.org.cn

2. 上海时代之光照明电器检测有限公司(代码 ZM) / 国家电光源质量检验检测中心(上海) / 国家灯具质量检验检测中心 / 国家轻工业灯具质量监督检测中心 / 上海市照明产品质量监督检验站

Shanghai Alpha Lighting Equipment Testing Ltd. (SQI_ZM) / National Center of Inspection and Testing on Electric Light Source Quality (Shanghai) / China National Lighting Fitting Quality Inspection and Testing Centre (CLTC) / National Center for Quality Supervision and Inspection of Light Industrial Luminaires / Shanghai Municipal Station of Quality Supervision and Test on Lighting Products

地址：上海市闵行区江月路 900 号 2 号楼　　邮编：201114
电话：021-54336162；54336173；54336181；54336227　　传真：021-54337200
E-mail：salt@sqi.org.cn；salt@saltnet.com.cn ；sdzg@sqi.org.cn
Address: 2nd Building, No.900, Jiangyue Rd., Minhang District, Shanghai　　Post: 201114
Tel: 021-54336162, 54336173, 54336181, 54336227　　Fax: 021-54337200
E-mail：salt@sqi.org.cn, salt@saltnet.com.cn, sdzg@sqi.org.cn

3. 机电产品质量检验所(代码 JD) / 上海市机电产品质量监督检验站

Institute of Quality Inspection of Mechanical and Electronic Products (SQI_JD) / Shanghai Municipal Station of Quality Supervision and Inspection of Mechanical and Electronic Products

地址：上海市静安区万荣路 918 号　　邮编：200072
电话：021-56035307；56652534　　传真：021-56652624
E-mail：jds@sqi.org.cn
Address: No.918, Wanrong Rd., Jing'an District, Shanghai　　Post: 200072
Tel: 021-56035307, 56652534　　Fax: 021-56652624
E-mail：jds@sqi.org.cn

4. 轻工与化工产品质量检验所(代码 QG、HG) /国家日用消费品质量检验检测中心 / 上海市轻工产品质量监督检验站 / 上海市化工产品质量监督检验站

Institute of Quality Inspection of Light Industrial Products and Chemical Products (SQI_QG/HG) / National Center of Quality Inspection and Testing on Consumer Goods / Shanghai Municipal Station of Quality Supervision and Inspection of Light Industrial Products / Shanghai Municipal Station of Quality Supervision and Inspection of Chemical Products

地址：上海市闵行区江月路 900 号 3 号楼　　邮编：201114
地址：上海市奉贤区平庄西路 3086 号　　邮编：201499
电话：021-54336172；54336175；54338258　　传真：021-54336175
E-mail：qgs@sqi.org.cn；qinggong@sqi.org.cn
Address: 3rd Building, No.900, Jiangyue Rd., Minhang District, Shanghai　　Post: 201114
Address: No.3086, West Pingzhuang Rd., Fengxian District, Shanghai　　Post: 201499
Tel: 021-54336172, 54336175, 54338258　　Fax: 021-54336175
E-mail：qgs@sqi.org.cn, qinggong@sqi.org.cn

5. 建材家居装饰装修质量检验所(代码 JC) / 国家家具质量检验检测中心 / 国家轻工业家具质量监督检测中心 / 国家轻工业建筑五金质量监督检测中心 / 国家建筑材料及装饰装修材料质量检验检测中心 / 上海市建筑材料及装饰装修材料质量监督检验站 / 上海市室内装饰质量监督检验站

Institute of Quality Inspection of Building Materials and Decoration Materials (SQI_JC) / National Center of Quality Inspection and Testing on Furniture / National Center for Quality Supervision and Inspection of Light Industrial Furniture / National Center for Quality Supervision and Inspection of Light Industrial Building Hardware / National Center of Quality Inspection and Testing on Building and Decoration Materials / Shanghai Municipal Station of Quality Supervision and Inspection of Building Materials and Decoration Materials / Shanghai Municipal Station of Quality Supervision and Inspection of Interior Decoration

地址：上海市闵行区江月路 900 号 5 号楼　　邮编：201114
电话：021-54336170；54336225　　传真：021-54336170
地址：上海市奉贤区平庄西路 3086 号　　邮编：201499
电话：021-57493115　　传真：021-57493162
E-mail: jcs@sqi.com.cn,jiancai@sqi.org.cn
Address: 5th Building, No.900, Jiangyue Rd., Minhang District, Shanghai　　Post: 201114
Tel: 021-54336170, 54336225　　Fax: 021-54336170
Address: No.3086, West Pingzhuang Rd., Fengxian District, Shanghai　　Post: 201499
Tel: 021-57493115　　Fax: 021-57493162
E-mail: jcs@sqi.com.cn, jiancai@sqi.org.cn

6. 电子电器家用电器质量检验所(代码 DZ、DQ) / 国家电器能效与安全质量检验检测中心 / 国家智能电网分布式电源装备质量检验检测中心(上海) / 上海市电子电器家用电器质量监督检验站

Institute of Quality Inspection of Electronics and Household Appliances (SQI_DZ/DQ) / National Center of Quality Inspection and Testing on Energy Efficiency and Safety of Electrical Appliance / National Center of Quality Inspection and Testing on Distributed Power Equipment in Smart Grid (Shanghai) / Shanghai Municipal Station of Quality Supervision and Inspection of Electronics and Household Appliances

地址：上海市闵行区江月路 900 号 4 号楼　　邮编：201114
电话：021-54336322；64336605　　传真：021-64313348
E-mail：dzs@sqi.org.cn
地址：上海市徐汇区苍梧路 381 号　　邮编：200233
电话：021-54263097；64336605　　传真：021-64850806
E-mail：dqs@sqi.org.cn
Address: 4th Building, No.900, Jiangyue Rd., Minhang District, Shanghai　　Post: 201114
Tel: 021-54336322, 64336605　　Fax: 021-64313348
E-mail：dzs@sqi.org.cn
Address: No.381, Cangwu Rd., Xuhui District, Shanghai　　Post: 200233
Tel: 021-54263097, 64336605　　Fax: 021-64850806
E-mail: dqs@sqi.org.cn

7. 计量检测所(代码 JL)

Institute of Metrology Inspection (SQI_JL)

地址：上海市闵行区江月路 900 号　　邮编：201114
电话：021-54336149；54336148　　传真：021-62892960
地址：上海市徐汇区永嘉路 627 号　　邮编：200031
电话：021-64372125　　传真：021-64372135
E-mail：jls@sqi.org.cn
Address: No.900, Jiangyue Rd., Minhang District, Shanghai　　Post: 201114
Tel: 021-54336149, 54336148　　Fax:021-62892960
Address: No.627, Yongjia Rd., Xuhui District, Shanghai　　Post: 200031
Tel: 021-64372125　　Fax: 021-64372135
E-mail：jls@sqi.org.cn

8. 纤维检验所(代码 XW) / 国家日用消费品质量检验检测中心 / 上海市纺织纤维质量监督检验站

Institute of Fiber Inspection (SQI_XW) / National Center of Quality Inspection and Testing on Consumer Goods / Shanghai Municipal Station of Quality Supervision and Inspection of Textile and Fiber

地址：上海市长乐路 1226 号 3 幢、4 幢　　邮编：200040
电话：021-62495465　　传真：021-62481025
E-mail：xws@sqi.org.cn
Address: 3rd Building / 4th Building, No.1226, Changle Rd., Shanghai　　Post: 200040
Tel: 021-62495465　　Fax: 021-62481025
E-mail：xws@sqi.org.cn